



Texas Commission on Environmental Quality

Protecting Texas by Reducing and Preventing Pollution

CERTIFICATE OF DELIVERY OF PUBLIC NOTICE TO CUSTOMERS

Public Water System (PWS) name: **R M S WSC**
PWS ID (7-digit number required): **1550136**
Type violation: **ARSENIC MCL, AVERAGE**
Time Period of violation: **second quarter of 2014**

The PWS named above has distributed the Public Notice (PN) for the type of violation and time period listed above by:

Mail or direct delivery, to bill-paying customers as required by 30 TAC §290.122(b)(2)(A) for community water systems; and

The information contained in this public notification is correct and complies with required public notification content in accordance with 30 TAC §290.122

and; Make an adequate good-faith effort to reach non-bill-paying consumers by appropriate methods (check all below that apply):

- Posting the PN on the internet at www. rmswater.webs.com
- Mailing the PN to postal patrons within the service area that do not receive a bill
- Advertising the PN in news media
- Publication of PN in local newspaper
- Posting the PN in public places
- Delivery of multiple copies to single bill addresses serving several persons
- Delivery to community organizations
- Email notification

Date of Delivery to Customers mailed on 7/3/14

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.”

Certified by: Name (print): Alisha Flanary Title: City Secretary
 Phone: 254-896-6501 Email: alisha@cityofriesel.org
 Signature: Alisha Flanary Date Signed: 7-3-14

Mail a copy of this completed form and a copy of the Public Notice that was delivered to your customers to:

TCEQ - Drinking Water Inventory & Enforcement Team
Attn: Public Notice (MC-155)
P. O. Box 13087
Austin, TX 78711-3087

RMS WATER SUPPLY COMPANY

PO BOX 249 – RIESEL, TX 76682

Meier's Settlement Water
Ronnie Dowdle, President
PO Box 95
RIESEL, TX 76682

Public Notice to Customers Type Violation:

Maximum Contaminant Level Violation MCL, AVERAGE / ARSENIC

The Texas Commission on Environmental Quality (TCEQ) has notified the [RMS WSC - PWS ID 1550136](#) water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (**MCL**) for **arsenic**. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for arsenic at 0.01 milligrams per liter (mg/L) based on running annual **average** (RAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for arsenic indicates a compliance value in [quarter TWO 2014 of 0.011 mg/L for EP001](#).

This is not an emergency. However, some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue: [The RMS WSC engineers are looking into treatment, blending, alternative water sources and other solutions, including the participation of a Regional Water Study through FHLM.](#)

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, contact: **BILL SHIPP** at **254-896-6501** or **254-424-6658**.

Sincerely,

Bill Shipp
RMS WSC Operator

Posted/Delivered on: **JULY 3, 2014**

RMS WATER SUPPLY COMPANY

PO BOX 249 – RIESEL, TX 76682

City of Riesel
Mayor Roger Fitzpatrick
PO Box 249
RIESEL, TX 76682

Public Notice to Customers Type Violation:

Maximum Contaminant Level Violation MCL, AVERAGE / ARSENIC

The Texas Commission on Environmental Quality (TCEQ) has notified the [RMS WSC - PWS ID 1550136](#) water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (**MCL**) for **arsenic**. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for arsenic at 0.010 milligrams per liter (mg/L) based on running annual **average** (RAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for arsenic indicates a compliance value in [quarter TWO 2014 of 0.011 mg/L for EP001](#).

This is not an emergency. However, some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue: [The RMS WSC engineers are looking into treatment, blending, alternative water sources and other solutions, including the participation of a Regional Water Study through FHLM.](#)

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, contact: **BILL SHIPP** at **254-896-6501** or **254-424-6658**.

Sincerely,

Bill Shipp
RMS WSC Operator

Posted/Delivered on: **JULY 3, 2014**